

BILLERICA FIRE DEPARTMENT FIRE PREVENTION BUREAU

8 Good St., Billerica, Massachusetts 01821 (978) 671-0940 Fax: (978) 671-0935

APPLICATION FOR LP PERMIT

DIG SAFE IN ACCORDANCE WITH THE PROVISIONS OF CHAPTER 148, G.L. AS PROVIDED IN SECTION 104 APPLICATION IS HEREBY MADE BY:
FIRM NAME:PHONE:
FIRM ADDRESS:
NAME OF INSTALLER/OPERATOR:(COPY OF LICENSE REQUIRED)
ADDRESS OF INSTALLATION:
FOR PERMISSION TO INSTALL:
TANKS GALLONS
IS THIS A TANK SWAP ONLY YES NO IS THIS PROPERTY LOCATED IN THE FLOOD PLAIN YES NO IS THIS A RETAIL EXCHANGE YES NO (PLEASE LIST NUMBER & SIZE OF TANKS BELOW)
NOTE: ALL Underground Tanks must meet NFPA – 58 (2011) 6.6.1.6 ALL Aboveground Tanks located in Flood Plain must meet NFPA – 58 (2011) 6.6.1.6
NO PERMITS ACCEPTED BY MAIL.
THE FOLLOWING MUST BE INCLUDED WITH THIS APPLICATION:
SITE DRAWING / PLOT PLAN WITH APPLICABLE MEASUREMENTS, PER NFPA – 58 CHAPTER 6 (INCLUDING VEHICLE PROTECTION).
APPLICATION FOR PERMIT DOES NOT ALLOW INSTALLATION UNTIL APPROVED BY F.P.B.
Permit Fee \$25.00 Installer's Signature



BILLERICA FIRE DEPARTMENT FIRE PREVENTION BUREAU

LIQUID PROPANE GAS CONTAINER INSTALLATION 527 CMR 6.00 INSPECTION CHECKLIST

Tank Owner:	***************************************				1	
Emergency Notification Visible:						
Storage: License Required for Site:	☐ Yes			nte: mt. Allowed:		
(Amount over 2,000 water gallons per site)	<u> </u>	LI NO A	RRIERAIE M	mt. Allowed.		
ACCESS AND PREMISES	YES/NO			COMMENTS		
Above Ground Installation	☐ Not Applicable					
Size of Containers:	Numbe	r of Contain	ers:	-		
Proper Location of Containers: Verify using NFPA #58 – 2011 Appendix 1 Diagrams and Clearances.		Yes	□ No	□ N/A		
Protected from Vehicles.		Yes	□ No	□ _{N/A}		
Under Ground Installation Not Applicable						
Note: The container needs to be inspected when set in the ground before backfilling.						
Size of Containers:	Number of	Containers	J			
Proper Location of Containers: Verify using NFPA - 98 – 2011 Appendix 1 Diagrams and Clearances.		☐ Yes	□ No	□ N/A		
Proper installation of containers: Verify using 527 CMR 1 and NFPA-98-2011 and Chapter-6 Appendix 1 diagrams for clearances		Yes	□ No	□ N/A		
Outside Storage / Resale and Exchange		☐ Not Applicable				
Verify using 527 CMR1 and NFPA #58-2011						
Proper Location of Containers:		Yes	☐ No	□ N/A		
Proper installation of containers:		☐ Yes	☐ No	□ N/A		
Proper vehicle damage protection		Yes	☐ No	□ N/A		